

Tamil Nadu Fire & Rescue Service Department

Certi. No: 18/2023
Date :03.05.2023

Fire & Rescue Station
Rasipuram – 637 408.

No Objection Certificate


Sub: Tamil Nadu Fire & Rescue Services – office of the Fire and Rescue station Rasipuram – Issued to no Objection Certificate for School Recognition – Regarding

Ref: 1. G.o.Ms.No.117 School of Education (2) Dept., Date:07.09.2004
2. G.o.Ms.No.122 School of Education (2) Dept., Date:14.09.2004
3.G.o.Ms.No.123 School of Education (2) Dept., Date:14.09.2004
4.**The Chairman, M/S Vetri Vikaas Public Scool (CBSE), Application Dated: 01.05.2023.**

With reference to the letter cited above, premises **M/S. VETRI VIKAAAS PUBLIC SCHOOL (CBSE), S.F.No:78/2A, 2B, T.S.No: 12/3A1, 3B, 6, Ward- B, Block – 10, Goundampalayam Village, Rasipuram Town & Taluk, Namakkal District was inspected by the Mr.V.Palagara Ramasamy, Station Officer, Rasipuram on 02.05.2023.** In the view of our Fire and Rescue service department there is No objection for the granting Recognition to the above said school. The License is valid for One Year.



The Chairman,
M/S.Vetri Vikaas Public School (CBSE),
S.F.No:78/2A, 2B, T.S.No: 12/3A1, 3B, 6,
Ward – B, Block – 10, Goundampalayam Village,
Rasipuram Town & Taluk,
Namakkal District.


Station Officer, 315123
Fire & Rescue Station,
Rasipuram – 637 408.

Copy : District Officer, Fire & Rescue service, Namakkal District.

Copy: Joint Director, Tamilnadu Fire & rescue Service, western Region, Kovai-18.

நிபந்தனைகள்

1. தேசிய கட்டிட விதியின் படி NOC-2016 PART - IV – ன் படி யணைப்பு-மீட்பு பணிகள் துறையினரால் குறிப்பிடப்பட்டுள்ளவாறு தீ தடுப்பு சாதனங்கள் அமைக்கப்பட வேண்டும்.
2. இந்திய தரக்கட்டுப்பாடு IS.2109 – 2010 – ன் படி தீயணைப்பாளர்கள் பொருத்தப்பட வேண்டும்.
3. தீ பாதுகாப்பிற்கென்று 10000 லிட்டர் கொள்ளளவு கொண்ட மேல்நிலை நீர் தேக்க தொட்டி ஒன்று அமைக்கப்பட வேண்டும்.
4. 450 LPM திறன் கொண்ட FIRE PUMP ஒன்றும் மேல்நிலை தொட்டியின் அருகில் அமைத்து Hose Reel Hose System பொருத்தப்பட வேண்டும்.
5. Manually Operated Electronic Fire Alarm System பொருத்தப்பட வேண்டும்.
6. தீ பாதுகாப்பிற்கு வைத்திருக்கும் தீயணைப்பாளர்களை கால முறையாக மறுநிரப்பம் செய்து எப்போதும் நல்ல நிலையில் இயங்க கூடியதாக வைக்கப்பட வேண்டும்.
7. அங்கீகரிக்கப்பட்ட தரமான மீன்சாதனங்கள் (ISI) சான்று பெற்றவை மட்டுமே பயன்படுத்த வேண்டும்.
8. வெளியேறும் வழி எப்போதும் தடையின்றி இருக்க வேண்டும்.
9. இந்த நிபந்தனைகள் ஏதேனும் மீறப்பட்டால் இந்த தடையின்மை சான்று தானாக ரத்தானதாக கருதப்படும் என விண்ணப்பதாரருக்கு தெரிவிக்கப்படுகிறது.

நிலைய அலுவலர்
தீயணைப்பு-மீட்பு பணிகள் நிலையம்
இராசிபுரம்-637 408.
நாமக்கல் மாவட்டம்.